



WHERE TO INSTALL SAFETY GLASS

CRITICAL LOCATIONS

Ordinary annealed glass may be used in small panes up to a maximum width of 250mm and an area not exceeding 0.5m². Such glass must not be less than 6mm in thickness, except in the case of traditional leaded lights and copper lights, where 4mm can be used.



CRITICAL LOCATIONS

1. GLAZING IN DOORS

Any glass within 1500mm from floor level including any glass in doors that does not start over 1500mm from the floor must be safety glass.

2. GLAZING ADJACENT TO DOORS

Any windows or glass panels within 300mm of the edge of a door and which is also wholly or partially within 1500mm from floor level must be safety glass.

3. LOW LEVEL GLAZING

Any other kind of glazing that is within 800mm from floor level. This means that windows that are not located within 300mm of a door must use safety glass if the bottom of the glazing is within 800mm of the floor level.